

**HYDRAULIC DESIGN
OF
WATER TREATMENT PLANT**

CAPACITY - 40 MLD

TABLE OF CONTENTS

<i>Hydraulic Design Of Cascade Aerator</i>	10
1. Inlet Shaft	10
2. Steps And Planner	10
3. Collection Launder	11
<i>Hydraulic Design Of Parshall Flume</i>	14
1. Parshall Flume	14
2. Upstream Channel	14
3 Downstream Channel	15
<i>Hydraulic Design Of Flash Mixer (Square With Distribution Chamber)</i>	19
1. Chamber	19
2. Power Requirement	20
3. Openings	21
<i>Hydraulic Design Of Pipe</i>	23
<i>Hydraulic Design Of Pipe</i>	25
<i>Hydraulic Design Of Clariflocculator</i>	28
1 Central Shaft	28
2. Flocculator	29
3. Power Requirement	30
4. Clarifier	32
5. Weir	33
6. Notches	33
7. Peripheral Launder	34
<i>Hydraulic Design Of Channel</i>	37
<i>Hydraulic Design Of Filter Inlet Channel</i>	39
<i>Hydraulic Design Of Rapid Sand Gravity Filter</i>	42
1. Filter Beds	42
2. Depth Of Sand And Gravel	43
3. Depth Of Water	43
4. Under Drain System	44
5. Backwashing Of Filter	46
6. Wash Water Trough	47
7. Gullet	48
8. Wash Water Tank	48
<i>Mechanical Design</i>	51
1. Filter Inlet	51
2. Filter Outlet	51
3. Wash Water Inlet	52
4. Wash Water Outlet	53
5. Air Blower Design	53
6. Wash Water Pump	54
<i>Hydraulic Design Of Pure Water Channel</i>	56
<i>Hydraulic Design Of Pipe</i>	58
<i>Hydraulic Design Of Sump - Circular</i>	61
<i>Hydraulic Design Of Chlorination</i>	63
1. Chlorinators	63
2. Emergency Chlorinators	63

3. Chlorine Room	64
Hydraulic Design Of Alum Units	66
1. Alum Requirements	66
2. Alum Solution Tanks	66
3. Preperation Of Solutions	66
4. Storage Space - Alum And Tcl Units	68
4.1 Tcl Requirements	68
4.2 Alum Requirements	68
Head Losses And Reduced Levels (Cascade Aerator)	74
1. Steps And Planner	74
2. Collection Launder	74
Head Losses And Reduced Levels (Parshall Flume)	76
1. Upstream Channel	76
2. Downstream Channel	77
Head Losses And Reduced Levels (Flash Mixer)	78
Head Losses And Reduced Levels (Pipe)	79
Head Losses And Reduced Levels (Pipe)	80
Head Losses And Reduced Levels (Clariflocculator)	81
1. Flocculator And Clarifier	81
2. Collection Launder	81
Head Losses And Reduced Levels (Channel)	83
Head Losses And Reduced Levels (Filter Inlet Channel)	84
Head Losses And Reduced Levels (Rapid Sand Gravity Filter)	85
Head Losses And Reduced Levels (Pure Water Channel)	86
Head Losses And Reduced Levels (Pipe)	87
Head Losses And Reduced Levels (Pure Water Sump)	88

99%

ANNEXURE - I

- STANDARD TABLES

STANDARD DIMENSIONS FOR PARSHALL FLUME

*(*Reference Manual on Sewerage and Sewerage Treatment- Table 5.5)*

Flow Range Q _{max} (MLD)	W	A	B	C	D	F	G	K	Z
Upto 5	75	460	450	175	255	150	300	25	56
5 to 30	150	610	600	315	391	300	600	75	113
30 to 45	225	865	850	375	566	300	750	75	113
45 to 170	300	1350	1322	600	831	600	900	75	225
170 to 250	450	1425	1357	750	1010	600	900	75	225
250 to 350	600	1500	1472	900	1188	600	900	75	225
350 to 500	900	1650	1619	1200	1547	600	900	75	225
500 to 700	1200	1800	1766	1500	1906	600	900	75	225
700 to 850	1500	2100	2060	2100	2625	600	900	75	225
850 to 1400	2400	2400	2353	2700	3344	600	900	75	225

STANDARD POWER REQUIREMENT*(*Reference IS 7090 - 4985)*

Detention Time	Velocity Gradient	Net Power Input per Unit Volume	Net power Input
Sec	S⁻¹	Watts/m³ Volume	Watts/m³ of flow per hr
60	300	72	1.2
50	360	104	1.4
40	450	162	1.8
30	600	288	2.4
25	720	415	2.9
20	900	648	3.6

***Calculations based on water temperature of 30 ° C*

ANNEXURE - II

- **HYDRAULIC DESIGN CALCULATIONS**

TABLE NO.1 - DESIGNED FLOWS AND CAPACITIES FOR VARIOUS ELEMENTS

SR NO.	ELEMENT	FLOW	NO. OF UNITS	OVERLOADING	LOSS
		MLD	NOS.	%	%
1	Cascade Aerator	40	1	20	5
2	Parshall Flume	40	1	20	5
3	Flash Mixer (Square DC)	40	2	20	5
4	Pipe	40	1	20	5
5	Clarriflocculator (Radial flow)	40	1	20	5
6	Channel	40	1	20	5
7	Rapid Sand Gravity Filter	40	1	20	5
8	Pure Water Channel	40	1	20	5
9	Pipe	40	1	20	5
10	Circular Sump	40	1	20	5

SR NO.	ELEMENT	DESIGNED FLOW / UNIT	CAPACITY / UNITS		
		MLD	m ³ /day	m ³ /hr	m ³ /sec
1	Cascade Aerator	50.000	50,000.000	2,083.333	0.579
2	Parshall Flume	50.000	50,000.000	2,083.333	0.579
3	Flash Mixer (Square DC)	25.000	25,000.000	1,041.667	0.289
4	Pipe	50.000	50,000.000	2,083.333	0.579
5	Clarriflocculator (Radial flow)	50.000	50,000.000	2,083.333	0.579
6	Channel	50.000	50,000.000	2,083.333	0.579
7	Rapid Sand Gravity Filter	50.000	50,000.000	2,083.333	0.579
8	Pure Water Channel	50.000	50,000.000	2,083.333	0.579
9	Pipe	50.000	50,000.000	2,083.333	0.579
10	Circular Sump	50.000	50,000.000	2,083.333	0.579

Formula Used:

1 **Designed Flow in MLD** $Designed\ Flow\ Per\ Unit = \frac{Flow \times \left[\frac{Overloading}{100} + \frac{Loss}{100} \right] + Flow}{No.\ of\ Units}$

2 **Capacity in m³/day** $Capacity\ (Q) = Designed\ Flow\ Per\ Unit \times 10^3$

3 **Capacity in m³/hr** $Capacity\ (Q) = \frac{Designed\ Flow\ Per\ Unit \times 10^3}{24}$

4 **Capacity in m³/sec** $Capacity\ (Q) = \frac{Designed\ Flow\ Per\ Unit \times 10^3}{24 \times 60 \times 60}$

HYDRAULIC DESIGN

- **INLET SHAFT**
- **STEPS AND PLANNER**
- **COLLECTION LAUNDER**

HYDRAULIC DESIGN OF CASCADE AERATOR

The role of Aeration is to remove undesirable dissolved gases in water and to add oxygen to water to convert undesirable substances to a more manageable form.

1. INLET SHAFT

(Reference Table No. 1)

- ✓ Number of Units = 1 Nos
- ✓ Designed Flow Per Unit = 50 MLD
- ✓ Designed Capacity in $m^3/sec = 0.579 m^3/sec$

1.1 ASSUMPTIONS & CALCULATIONS:

- Assumed velocity of flow through Inlet Shaft = 0.65 m/sec

$$\begin{aligned}
 \text{Diameter of Inlet Shaft Required} &= \left[\frac{4 \times \text{Designed Flow (m}^3/\text{sec)}}{\pi \times \text{Velocity (m/s)}} \right]^{0.5} \\
 &= \left[\frac{4 \times 0.579}{3.14 \times 0.65} \right]^{0.5} \\
 D_{\text{Required}} &= 1.065 \text{ m}
 \end{aligned}$$

Provided Internal Diameter of Inlet Shaft = 1.1 m

- Assumed thickness of Inlet Shaft = 0.1 m

Hence, Outer Diameter = 1.300 m

1.2 VALIDATION CHECKS:

1. Provided Diameter 1.1 m > Required Diameter = 1.065 m

Diameter Provided > Diameter Required.

2. Velocity Achieved = 0.610 m/sec

Hence, Velocity achieved is within the permissible Range (0.6 -1.25m/sec)

DESIGN SUMMARY - INLET SHAFT

Velocity	=	0.610 m/sec
Internal Diameter of Inlet Shaft	=	1.1 m
Thickness of Inlet Shaft	=	0.1 m
Outer Diameter of Inlet Shaft	=	1.300 m

2. STEPS AND PLANNER

(Reference Table No. 1)

- ✓ Number of Units = 1 Nos
- ✓ Designed Flow Per Unit = 50 MLD
- ✓ Designed Capacity in $m^3/hr = 2,083.333 m^3/hr$

2.1 ASSUMPTIONS & CALCULATIONS:

- Assumed criteria for area of Aerator = $0.015 m^2/m^3/h$

$$\text{Area of Aerator Required} = \text{Designed Flow (m}^3/\text{hr)} \times \text{Criteria (m}^2/\text{m}^3/\text{h)}$$

$$= 2,083.333 \times 0.015$$

$$Area_{Required} = 31.250 \text{ m}^2$$

Provide Area of Aerator = 32 m²

$$Diameter \text{ of Aerator} = \sqrt{\frac{4}{\pi} \times A + O.D^2}$$

$$= \sqrt{\frac{4}{\pi} \times 32 + 1.300^2}$$

$$Diameter \text{ of Aerator} = 6.516 \text{ m}$$

- Assumed Number of steps = 5 NOS
- Assumed Rise of each step = 0.3 m

$$Size \text{ of Tread} = \frac{Diameter \text{ of Aerator} - O.D_{Shaft}}{2 \times No. \text{ of Steps}}$$

$$= \frac{6.516 - 1.300}{2 \times 5}$$

$$Size \text{ of Tread} = 0.522 \text{ m}$$

Provided Tread= 0.6 m

$$Actual \text{ Diameter of Aerator} = Tread_{Provided} \times (2 \times No. \text{ of Steps}) + O.D_{Shaft}$$

$$= 0.6 \times (2 \times 5) + 1.300$$

$$Actual \text{ Diameter of Aerator} = 7.300 \text{ m}$$

$$Total \text{ Height of Rise} = Rise \times No. \text{ of Steps}$$

$$= 0.3 \times 5$$

$$Total \text{ Height of Rise} = 1.5 \text{ m}$$

VALIDATION CHECKS:

Actual Area Criteria = 0.020 m²/m³/h

Actual Area Criteria achieved is within the permissible Limit
(0.015 to 0.045 m²/m³/h)

DESIGN SUMMARY - STEPS & PLANNER

Actual Area Criteria	=	0.020 m ² /m ³ /h
Diameter of Aerator	=	7.300 m
Number of Steps	=	5 NOS
Tread Size	=	0.6 m
Rise Size	=	0.3 m
Total Rise height	=	1.5 m

3. COLLECTION LAUNDRER

- ✓ Number of Units = 1 Nos
- ✓ Designed Flow Per Unit = 50 MLD

✓ *Designed Capacity in m³/sec = 0.579 m³/sec*

3.1 ASSUMPTIONS & CALCULATIONS:

- Assumed velocity of flow = 0.65 m/sec
- Assumed width of collecting Launder = 0.6 m
- Assumed Free Board = 0.3 m

$$\begin{aligned}
 \text{Side Water Depth of Collection Launder} &= \frac{\text{Design Flow}(m^3/sec)}{2 \times \text{Velocity} \times \text{Width of Launder}} \\
 &= \frac{0.579}{2 \times 0.65 \times 0.6} \\
 SWD_{Launder} &= 0.742 \text{ m}
 \end{aligned}$$

$$\begin{aligned}
 \text{Total Depth of Collection Launder} &= SWD_{Launder} + \text{Free Board} \\
 &= 0.742 + 0.3
 \end{aligned}$$

$$\text{Total Depth of Collection Launder} = 1.042 \text{ m}$$

DESIGN SUMMARY - COLLECTION LAUNDER	
Velocity	= 0.65 m/sec
Width	= 0.6 m
Side water Depth (SWD)	= 0.742 m
Free Board	= 0.3 m
Total Depth of Launder	= 1.042 m




Figure - Cascade Aerator Details

*For Schematic purpose only

HYDRAULIC DESIGN

- PARSHALL FLUME
- UPSTREAM CHANNEL
- DOWNSTREAM CHANNEL

HYDRAULIC DESIGN OF PARSHALL FLUME


The role of Parshall Flume (U/S & D/S Channel) is to measure the flow and convey water from Aerator to Flash mixer. Parshall Flume is a type of standing wave flume which is widely used. It can measure discharges varying from 0.001 m³/sec to 100 m³/sec.

1. PARSHALL FLUME

(Reference Table No. 1)

- ✓ Number of Units = 1 Nos
- ✓ Designed Flow Per Unit = 50 MLD

1.1 STANDARD DIMENSIONS:



All above mentioned dimensions are in mm.

1.2 DIMENSIONS OF PARSHALL FLUME:

(*Reference Manual on Sewerage and Sewerage Treatment- Table 5.5)

W	A	B	C	D	F	G	K	Z
300	1350	1322	600	831	600	900	75	225

*All above mentioned dimensions are in mm.

2. UPSTREAM CHANNEL

(Reference Table No. 1)

- ✓ Designed Capacity in m³/sec = 0.579 m³/sec

2.1 ASSUMPTIONS & CALCULATIONS:

- Assumed Velocity of Flow = 0.65 m/sec
- Assumed Free Board = 0.3 m
- Assumed Length of Channel = 2.5 m

SOME PAGES ARE KEPT BLANK INTENTIONALLY

HYDRAULIC DESIGN

- **CENTRAL SHAFT**
- **FLOCCULATOR**
- **POWER REQUIREMENT**
- **CLARIFIER**
- **WEIR**
- **NOTCHES**
- **PERIPHERAL LAUNDER**

TYPICAL CLARIFLOCCULATOR SKETCH




Figure - Clariflocculator Details

*For Schematic purpose only.

HYDRAULIC DESIGN OF CLARIFLOCCULATOR

1 CENTRAL SHAFT

The role of Central Shaft is to convey water to the clariflocculator.
 (Reference Table No. 1)

- ✓ Number of Units = 1 Nos
- ✓ Designed Flow Per Unit = 50.000 MLD
- ✓ Designed Capacity in $m^3/sec = 0.579 m^3/sec$

1.1.1 ASSUMPTIONS & CALCULATIONS:

➤ Assumed velocity of flow through Central Shaft = 0.65 m/sec

$$\begin{aligned}
 \text{Diameter Of Central Shaft Required} &= \left[\frac{4 \times \text{Designed Flow (m}^3/\text{sec)}}{\pi \times \text{Velocity (m/s)}} \right]^{0.5} \\
 &= \left[\frac{4 \times 0.579}{3.14 \times 0.65} \right]^{0.5}
 \end{aligned}$$

$$\text{Diameter Of Central Shaft Required} = 1.065 \text{ m}$$

Provide Internal Diameter of Central Shaft = 1.1 m

➤ Assumed thickness of Central Shaft = 0.15 m

Hence, Outer Diameter = 1.400 m

1.1.2 VALIDATION CHECKS:

1. Provided Diameter = 1.1 m > Required Diameter = 1.065 m

Hence, Diameter provided of Central Shaft is Sufficient.

2. Velocity Achieved = 0.610 m/s

Hence, Velocity achieved is within the permissible Range(0.6-1.2m/sec).

DESIGN SUMMARY - CENTRAL SHAFT

Velocity	=	0.610 m/sec
Internal Diameter of Central Shaft	=	1.1 m
Thickness of Central Shaft	=	0.15 m
Outer Diameter of Central Shaft	=	1.400 m

1.2 PORTS

Ports are being provided at the top portion of the Central shaft with the purpose for outlet of water.
 (Reference Table No. 1)

- ✓ Number of Units = 1 Nos
- ✓ Designed Flow Per Unit = 50.000 MLD
- ✓ Designed Capacity in $m^3/sec = 0.579 m^3/sec$

1.2.1 ASSUMPTIONS & CALCULATIONS:

➤ Assumed velocity of flow through Ports = 0.65 m/sec

$$\text{Area of Openings of Ports} = \frac{\text{Design Flow (m}^3/\text{sec)}}{\text{Velocity (m/sec)}}$$

$$= \frac{0.579}{0.65}$$

$$\text{Area of Openings of Ports} = 0.891 \text{ m}^2$$

- Assumed Number of Rows = 1 Nos.
- Assumed Number of Ports per Rows = 5 Nos.
- Assumed width of port = 0.541 m
- Assumed Clear Spacing of Ports = 0.150 m

$$\text{Area of each port required} = \frac{\text{Area of Openings of Ports}}{\text{Nos. of Rows} \times \text{Nos. of Ports per Row}}$$

$$= \frac{0.891}{1 \times 5}$$

$$\text{Area of each port required} = 0.178 \text{ m}^2$$

$$\text{Height of port} = \frac{\text{Area of port required}}{\text{width of port}}$$

$$= \frac{0.178}{0.541}$$

$$\text{Height of port} = 0.329 \text{ m}$$

Provide height of port = 0.35 m

$$\text{Actual Clear Spacing of Ports} = \frac{(\pi \times \text{I.D}) - (\text{Width of Port} \times \text{No. of Ports per Row})}{\text{No. of Ports per Row}}$$

$$= \frac{(3.14 \times 1.1) - (0.541 \times 5)}{5}$$

$$\text{Actual Clear Spacing of Ports} = 0.150 \text{ mm c/c}$$

NOTE: For ease in construction of ports, clear spacing is maintained as a standard value and thereby width of port is calculated accordingly

1.2.2 VALIDATION CHECKS:

1. Provided Area of Ports = 0.189 m^2 > Required Area = 0.178 m^2

Hence, Dimensions of Ports are Sufficient.

DESIGN SUMMARY - PORTS

Velocity through Ports	=	0.65 m/sec
No. of Rows	=	1 Nos.
Number of Ports per Row	=	5 Nos.
Height of Port	=	0.35 m
Width of Port	=	0.541 m
Actual Clear Spacing Between Ports	=	0.150 m

2. FLOCCULATOR

The role of flocculator is to agglomerate the macroflocs generated in the Flash Mixer. The agglomeration helps to build large size and dense flocs which are effectively removed in the Clarifier/Sedimentation Tank. (Reference Table No. 1)

- ✓ Number of Units = 1 Nos
- ✓ Designed Flow Per Unit = 50.000 MLD
- ✓ Designed Capacity in m³/sec = 0.579 m³/sec

2.1 ASSUMPTIONS & CALCULATIONS:

- Assumed Detention Time in Flocculator = 20 minutes
- Assumed SWD in Flocculator = 4.5 m

$$\begin{aligned} \text{Volume of Flocculator} &= \text{Design Flow} \times \text{Detention Time} \times 60 \\ &= 0.579 \times 20 \times 60 \end{aligned}$$

$$\text{Volume of Flocculator} = 694.800 \text{ m}^3$$

$$\begin{aligned} \text{Diameter of Flocculator Required} &= \left[\frac{4}{\pi} \times \left[\frac{\text{Volume (m}^3\text{)}}{\text{SWD (m)}} + O. D_{\text{shaft}}^2 \right] \right]^{0.5} \\ &= \left[\frac{4}{3.14} \times \left[\frac{694.800}{4.5} + 1.400^2 \right] \right]^{0.5} \\ D_{F \text{ Required}} &= 14.091 \text{ m} \end{aligned}$$

Provide Diameter of Flocculator(D_F) = 15 m

2.2 VALIDATION CHECKS:

- 1. Actual Detention Time Maintained = 22.891 > Assumed Detention time = 20 min

Actual Detention Time Maintained > Assumed Detention Time.

DESIGN SUMMARY - FLOCCULATOR

Detention Time	=	20 min
Side Water Depth (SWD _F)	=	4.5 m
Diameter of Flocculator (D _F)	=	15 m

3. POWER REQUIREMENT

- Assumed Velocity Gradient = 30 sec⁻¹
- Assumed absolute Viscosity of Water = 0.00089 kg/m.s

$$\begin{aligned} \text{Power Required} &= G^2 \times \mu \times \frac{\pi}{4} \times \left(D_F^2 - OD_{\text{shaft}}^2 \right) \times SWD_F \\ &= 30^2 \times 0.00089 \times \frac{3.14}{4} \times \left(15^2 - 1.400^2 \right) \times 4.5 \\ \text{Power Required} &= 0.631 \text{ kw} \end{aligned}$$

3.1 PADDLE & BLADE REQUIREMENT:

- Assumed Drag Coefficient = 1.1
- Assumed Density of Water = 997 kg/m³
- Assumed Paddle Tip Velocity = 0.5 m/sec
- Assumed Water Velocity at Paddle Tip = 0.125 m/sec
 (*As per CPEEHO Manual Water Velocity at Paddle tip should be 25% of Paddle tip Velocity.)
- Assumed Number of Drive Units = 2 Nos.
- Assumed Number of Arms per Drive Unit = 4 Nos.
- Assumed Number of Blades = 4 Nos.

$$\begin{aligned}
 \text{Area of Paddles Required} &= \frac{2P}{C_D \times \rho \times (V - v)^3} \\
 &= \frac{2 \times 0.631 \times 10^3}{1.1 \times 997 \times (0.5 - 0.125)^3} \\
 A_p &= 21.821 \text{ m}^2
 \end{aligned}$$

$$\begin{aligned}
 \text{Area of Blades/Drive Unit} &= \frac{A_p}{\text{Number of Drives}} \\
 &= \frac{21.821}{2}
 \end{aligned}$$

$$\text{Area of Blades/Drive Unit} = 10.911 \text{ m}^2$$

**Note : For Detail Calculation & Diagram Refer Annexure III*

- Assumed Height of Blades = 1.4 m
- Assumed Width of Blades = 0.3 m
- Assumed rpm of Blade = 3 rpm

$$\begin{aligned}
 \text{Area of Each Blade} &= \text{Height of Blade} \times \text{Width of Blade} \\
 &= 1.4 \times 0.3 \\
 \text{Area of Each Blade} &= 0.420 \text{ m}^2
 \end{aligned}$$

3.2 VALIDATION CHECKS:

1. Ratio of $A_{\text{blades to C/S}}$ Area of Flocculator = 10.980 %

The Ratio is in between 10 to 25% which is permissible Limit.

DESIGN SUMMARY - POWER, PADDLE & BLADES	
Velocity Gradient	= 30 sec ⁻¹
Power Required	= 0.631 kw
Drag Coefficient	= 1.1
Paddle Tip Velocity	= 0.5 m/sec
Water Velocity at Paddle Tip	= 0.125 m/sec
No. of Drive Units	= 2 Nos.
No. of Arms per Drive Units	= 4 Nos.
No of Blade per Arm	= 4 Nos.
Height of Blade	= 1.4 m
Width of Blade	= 0.3 m
rpm of Blade	= 3 rpm




Figure - Typical Flocculator Diagram

*For schemantic purpose only

4. CLARIFIER

The role of Clarifier is very similar of that of sedimentation tank. Clarifier is the unit in between Flocculator and Filtration Unit.

(Reference Table No. 1)

- ✓ Number of Units = 1 Nos
- ✓ Designed Flow Per Unit = 50.000 MLD
- ✓ Designed Capacity in m³/hr = 2,083.333 m³/hr

4.1 ASSUMPTIONS & CALCULATIONS:

- Assumed Slope to Horizontal = 1 in 11
- Assumed Detention Time in Flocculator = 2.5 hours
- Assumed SWD in Clarifier = 3 m
- Assumed Thickness of partition = 0.2 m
- Assumed Surface Overflow Rate (SOR) = 30 m³/m².d

$$\begin{aligned} \text{Volume of Clarifier} &= \text{Designed Capacity} \times \text{Detention Time} \\ &= 2,083.333 \times 2.5 \end{aligned}$$

$$\text{Volume of Clarifier} = 5,208.333 \text{ m}^3$$

$$\begin{aligned} \text{Area Of Clarifier} &= \frac{Q}{SWD} \\ &= \frac{5208.3333}{3} \end{aligned}$$

$$\text{Area Of Clarifier} = 1,736.111 \text{ m}^2$$

$$\begin{aligned} \text{Diameter of Clarifier Required} &= \left[\frac{4}{\pi} \times A + Df^2 \right]^{0.5} \\ &= \left[\frac{4}{3.14} \times 1,736.111 + 15^2 \right]^{0.5} \\ D_{C \text{ Required}} &= 49.21 \text{ m} \end{aligned}$$

SOME PAGES ARE KEPT BLANK INTENTIONALLY

HYDRAULIC DESIGN

- **FILTER BED**
- **SAND AND GRAVEL**
- **DEPTH OF WATER**
- **UNDER DRAIN SYSTEM**
- **BACKWASHING OF FILTER**
- **WASH WATER THROUGH**
- **GULLET/GUTTER**
- **WASH WATER TANK**




Figure - Rapid Sand Gravity

HYDRAULIC DESIGN OF RAPID SAND GRAVITY FILTER

1. FILTER BEDS

(Reference Table No. 1)

- ✓ Number of Units = 1 Nos.
- ✓ Designed Flow Per Unit = 50.000 MLD

1.1 ASSUMPTIONS & CALCULATIONS:

- Assumed Water for Backwashing = 5 %
- Cumulative Time for Backwashing = 10 min
- Assumed Number of Filter Beds = 2 Nos.
- Assumed Rate of Filtration in $20 \text{ m}^3/\text{m}^2 \cdot \text{h}$
- Assumed Ratio of Length to Width = 1.3

$$\begin{aligned} \text{Total Water to be Filtered} &= \text{Designed Capacity} + \text{Water for Backwashing} \\ &= 50.000 + \left[\frac{5 \times 50.000}{100} \right] \times 10^3 \end{aligned}$$

$$\text{Total Water to be Filtered} = 52,500.000 \text{ m}^3/\text{day}$$

$$\begin{aligned} \text{Actual Time for Filtration} &= 24 - \frac{\text{Time for Backwashing}}{60} \\ &= 24 - \frac{10}{60} \end{aligned}$$

$$\text{Actual Time for Filtration} = 23.833 \text{ Hours}$$

$$\begin{aligned} \text{Flow per Bed} &= \frac{\text{Total Water to be Filtered}}{\text{Actual Time for Filtration}} \\ &= \frac{52,500.000}{23.833} \end{aligned}$$

$$\text{Flow per Bed} = 2,202.797 \text{ m}^3/\text{hr}$$

$$\begin{aligned} \text{Area Required for each Bed} &= \frac{\text{Flow per Bed (m}^3/\text{hr)}}{\text{Rate of Filtration (m}^3/\text{m}^2 \cdot \text{h)} \times \text{No of Beds}} \\ &= \frac{2202.797}{20 \times 2} \end{aligned}$$

$$\text{Area Required for each Bed} = 55.070 \text{ m}^2$$

$$\begin{aligned} \text{Length of Bed Required} &= \left[\frac{\text{Area Required (m}^2)}{1/(L/W \text{ Ratio})} \right]^{0.5} \\ &= \left[\frac{55.070}{1/1.3} \right]^{0.5} \end{aligned}$$

$$\text{Length of Bed Required} = 8.461 \text{ m}$$

Provide Length of Bed = 8.5 m

$$\begin{aligned} \text{Width of Bed Required} &= \frac{\text{Length Required}}{\text{Ratio}} \\ &= \frac{8.461 \text{ m}}{1.3} \\ \text{Width of Bed Required} &= 6.509 \text{ m} \end{aligned}$$

Provide Width of Bed = 6.6 m

1.2 VALIDATION CHECKS:

1. Area Provided = 56.100 m² > Area Required = 55.070 m²

Area Provided > Area Required

2. Actual L/W ratio maintained is 1.288

Actual L/W ratio maintained is within the permissible range.(1.11 to 1.66)

DESIGN SUMMARY - FILTER BED	
Water for Backwashing	= 5 %
Time for Backwashing	= 10 min
Number of Filter Beds	= 2 Nos.
Rate of filtration	= 20 m ³ /m ² .h
L/W ratio	= 1.288
Length of filter bed	= 8.5 m
Width of filter Bed	= 6.6 m

2. DEPTH OF SAND AND GRAVEL

DESIGN SUMMARY - SAND	
Depth of Sand	= 0.6 m
d ₁₀ Size	= 0.6 mm
d ₆₀ Size	= 0.75 mm

SR.NO	RANGE IN SIZE (mm)	RANGE IN DEPTH (mm)	PROVIDED DEPTH (mm)
1	2 to 5	50 to 80	70
2	5 to 12	50 to 80	50
3	12 to 20	80 to 130	100
4	20 to 38	80 to 130	120
5	38 to 65	130 to 200	160

DESIGN SUMMARY - GRAVEL	
Depth of Gravel	= 500 mm

3. DEPTH OF WATER

3.1 ASSUMPTIONS & CALCULATIONS:

- Assumed Depth of water above sand = 1 m
- Assumed Free Board = 0.5 m

$$\begin{aligned} \text{Total Depth of Filter Box} &= D_{\text{Sand}} + D_{\text{Gravel}} + D_{\text{Water}} + \text{Free Board} \\ &= 0.6 + 0.5 + 1 + 0.5 \\ \text{Total Depth of Filter Box} &= 2.600 \text{ m} \end{aligned}$$

DESIGN SUMMARY - DEPTH OF WATER		
Depth of Water	=	1 m
Free Board	=	0.5 m
Total Depth of Filter Box	=	2.600 m

4. UNDER DRAIN SYSTEM*(Reference from Filter Bed Design)*✓ *Provided Length of Filter Bed = 8.5 m*✓ *Provided Width of Filter Bed = 6.6 m***4.1 ASSUMPTIONS & CALCULATIONS:**

- *Assumed Sections per filter bed = 2 Nos.*
- *Assumed Ratio of Filter to Perforations = 0.3 %*
- *Assumed Ratio of Laterals to Area of Orifice = 4*
- *Assumed Ratio of Area of Manifolds to Area of Laterals = 1.5*

$$\begin{aligned} \text{Area of filter per underdrain section} &= \text{Length of Filter} \times \frac{\text{Width of Filter}}{\text{No. of Underdrain sections/Filter Bed}} \\ &= 8.5 \times \frac{6.6}{2} \end{aligned}$$

$$\text{Area of filter per underdrain section} = 28.050 \text{ m}^2$$

$$\begin{aligned} \text{Area of Orifice Required} &= \text{Ratio of Filter to Perforations} \times \text{Area of Filter/Underdrain Section} \\ &= \frac{0.3}{100} \times 28.050 \end{aligned}$$

$$\text{Area of Orifice Required} = 0.084 \text{ m}^2$$

$$\begin{aligned} \text{Area of Lateral Required} &= \text{Ratio of Lateral to Area of Orifice} \times \text{Area of Orifice} \\ &= 4 \times 0.084 \end{aligned}$$

$$\text{Area of Lateral Required} = 0.336 \text{ m}^2$$

$$\begin{aligned} \text{Area of Manifold Required} &= \text{Ratio of Area of Manifold to Area of Lateral} \times \text{Area of Lateral} \\ &= 1.5 \times 0.336 \end{aligned}$$

$$\text{Area of Manifold Required} = 0.504 \text{ m}^2$$

$$\begin{aligned} \text{Diameter of Manifold Required} &= \left[\frac{4 \times A_{\text{Manifold}}}{\pi} \right]^{0.5} \\ &= \left[\frac{4 \times 0.504}{3.14} \right]^{0.5} \end{aligned}$$

$$\text{Diameter of Manifold Required} = 0.801 \text{ m}$$

Provide Diameter of Manifold = 0.85 m
--

➤ *Assumed width of Pit for Manifold = 0.9 m*➤ *Assumed height of Pit for Manifold = 0.9 m*

➤ Assumed Diameter of Laterals = 50 mm

$$\begin{aligned} \text{Area of each Lateral} &= \frac{\pi}{4} \times D_{Lateral}^2 \\ &= \frac{3.14}{4} \times 50^2 \end{aligned}$$

$$\text{Area of each Lateral} = 0.00196 \text{ m}^2$$

$$\begin{aligned} \text{Number of Laterals Required} &= \frac{\text{Area of Laterals}}{\text{Area of Each Lateral}} \\ &= \frac{0.336}{0.00196} \end{aligned}$$

$$\text{Number of Laterals Required} = 171 \text{ Nos}$$

Provide Number of Laterals = 172 Nos

$$\begin{aligned} \text{Number of Laterals on each side of} \\ \text{Manifold} &= \frac{\text{Number of Lateral}}{2} \\ &= \frac{171}{2} \end{aligned}$$

$$\text{Number of Laterals on each side of} \\ \text{Manifold} = 85.500 \text{ Nos}$$

$$\begin{aligned} \text{Length of Each Lateral} &= \frac{\frac{\text{Width of Filter Bed}}{2} - D_{Manifold}}{2} \\ &= \frac{\frac{6.6}{2} - 0.85}{2} \end{aligned}$$

$$\text{Length of Each Lateral} = 1.225 \text{ m}$$

$$\begin{aligned} \text{Ratio} &= \frac{\text{Length of Each Lateral}}{\text{Diameter of Lateral}} \\ &= \frac{1225}{50} \end{aligned}$$

$$\text{Ratio} = 24.500 < 60$$

$$\begin{aligned} \text{Required Spacing of Lateral} &= \frac{\text{Length of Filter Bed}}{(\text{Number of Lateral}/2)} \\ &= \frac{8.5}{(172/2)} \end{aligned}$$

$$\text{Required Spacing of Lateral} = 100 \text{ mm}$$

Provide Spacing of Lateral = 100 m c/c

➤ Assumed diameter of Orifice = 7 mm

$$\begin{aligned} \text{Area of each Orifice} &= \frac{\pi}{4} \times D_{\text{Orifice}}^2 \\ &= \frac{3.14}{4} \times 7^2 \end{aligned}$$

$$\text{Area of each Orifice} = 0.0000385 \text{ m}^2$$

$$\begin{aligned} \text{Number of Orifices per Lateral Required} &= \frac{\text{Area of Orifice}}{\text{No of Laterals} \times \text{Area of Each Orifice}} \\ &= \frac{0.084}{171 \times 0.0000385} \end{aligned}$$

$$\text{Number of Orifices per Lateral Required} = 14 \text{ Nos}$$

Provide Number of Orifices = 15 NOS

$$\begin{aligned} \text{Required Spacing of Orifice} &= \frac{\text{Length of Each Lateral}}{(\text{No of Orifice}/2)} \\ &= \frac{1.225}{(15/2)} \end{aligned}$$

$$\text{Required Spacing of Orifice} = 165 \text{ mm c/c}$$

Provide Spacing of Orifice = 140 mm c/c

4.2 VALIDATION CHECKS:

1. Diameter of Manifold Provided = 0.85 m > Diameter of Manifold required = 0.801 m

Spacing of Manifold Provided > Spacing of Manifold Required

2. Ratio of Length of Laterals to Spacing of Lateral = 24.500

Ratio of Length of Laterals to Spacing of Lateral < 60, Hence Okay.

DESIGN SUMMARY - UNDER DRAIN SYSTEM

Sections per filter bed	=	2 Nos
Ratio of Filter to Perforation	=	0.3 %
Ratio of Area of Manifolds to Area of Laterals	=	1.5
Diameter of Manifold	=	0.85 m
Width of Manifold Pit	=	0.9 m
Depth of Manifold Pit	=	0.9 m
Diameter of Lateral	=	50 mm
Number of Laterals	=	172 Nos
Diameter of Orifice	=	7 mm
Spacing of Lateral	=	100 mm c/c
Spacing of Orifice	=	140 mm c/c

5. BACKWASHING OF FILTER

SOME PAGES ARE KEPT BLANK INTENTIONALLY

HYDRAULIC DESIGN

- PURE WATER CHANNEL

HYDRAULIC DESIGN OF PURE WATER CHANNEL

The role of Pure Water Channel is to convey water from one element to the another.

(Reference Table No. 1)

- ✓ Number of Units = 1 Nos
- ✓ Designed Flow Per Unit = 50 MLD
- ✓ Designed Capacity in m³/sec = 0.579 m³/sec

1.1 ASSUMPTIONS & CALCULATIONS:

- Assumed velocity of flow through Pure Water Channel = 0.6 m/sec
- Assumed Width of Pure Water Channel = 2 m
- Assumed Free Board = 2 m
- Assumed Length of Pure Water Channel = 3 m

$$\begin{aligned} \text{Side Water Depth of Pure Water Channel} &= \frac{\text{Designed Capacity (m}^3/\text{sec)}}{\text{Velocity} \times \text{Width of Channel}} \\ &= \frac{0.579}{0.6 \times 2} \end{aligned}$$

$$\text{Side Water Depth of Pure Water Channel} = 0.482 \text{ m}$$

$$\begin{aligned} \text{Total Depth of Pure Water Channel} &= \text{SWD}_{\text{Channel}} + \text{Free Board} \\ &= 0.482 + 2 \end{aligned}$$

$$\text{Total Depth of Pure Water Channel} = 2.482 \text{ m}$$

1.2 VALIDATION CHECKS:

1. Velocity Achieved = 0.6 m/s

Hence, Velocity achieved is within the permissible Range (0.6 -1.2 m/sec)

DESIGN SUMMARY - CHANNEL	
Velocity	= 0.6 m/sec
Width	= 2 m
Side water Depth (SWD)	= 0.482 m
Length	= 3 m
Free Board	= 2 m
Total Depth of Pure Water Channel	= 2.482 m




Figure - Pure Water Channel Details

HYDRAULIC DESIGN

● PIPE

HYDRAULIC DESIGN OF PIPE

The role of Pipe is to convey water from one element to the another.

(Reference Table No. 1)

- ✓ Number of Units = 1 Nos
- ✓ Designed Flow Per Unit = 50 MLD
- ✓ Designed Capacity in m³/sec = 0.579 m³/sec

1.1 ASSUMPTIONS & CALCULATIONS:

➤ Assumed velocity of flow through Pipe = 0.6 m/sec

$$\begin{aligned}
 \text{Diameter of Pipe Required} &= \left[\frac{4 \times \text{Designed Flow (m}^3/\text{sec)}}{\pi \times \text{Velocity (m/s)}} \right]^{0.5} \\
 &= \left[\frac{4 \times 0.579}{3.14 \times 0.6} \right]^{0.5} \\
 \text{Diameter of Pipe Required} &= 1.108 \text{ m}
 \end{aligned}$$

Provide Standard D.I Pipe of Internal Diameter = 1.200 m

➤ Corresponding thickness of Pipe (K7) = 0.01530 m

Hence, Outer Diameter = 1.231 m

1.2 VALIDATION CHECKS:

1. Provided Diameter 1.200 m > Required Diameter = 1.108 m

Hence Diameter provided of Pipe is Sufficient.

2. Velocity Achieved = 0.512 m/s

DESIGN SUMMARY - PIPE	
Velocity	= 0.512 m/s
Internal Diameter of Pipe	= 1.200 m
Thickness of Pipe	= 0.01530 m
Outer Diameter of Pipe	= 1.231 m




Figure - Pipe Details
*For Schematic purpose only.

HYDRAULIC DESIGN

- PURE WATER SUMP (CIRCULAR)

SOME PAGES ARE KEPT BLANK INTENTIONALLY

ANNEXURE - II

- **HYDRAULIC HEAD LOSSES AND REDUCED LEVELS**

HYDRAULIC HEAD LOSSES AND REDUCED LEVELS	
NOTATION	ABBREVIATION
HL	Head Loss
TWL	Total Water Level
FSL	Full Supply Level
RL	Reduced Level
h_{fr} , h_f	Frictional Loss
g	Gravitational Acceleration
C	Manning's Coefficient
f	Hazen William Coefficient
R	Hydraulic Radius
S	Hydraulic Gradient
h_{en}	Head Loss at Entry
h_{ex}	Head Loss at Exit
h_b	Head Loss due to Bend
h_{se}	Head Loss due to Sudden Expansion
h_{sc}	Head Loss due to Sudden Contraction
K_{en}	Entry Head Loss Coefficient
K_{ex}	Exit Head Loss Coefficient
K_b	Bend Head Loss Coefficient
K_{se}	Expansion Head Loss Coefficient
K_{sc}	Contraction Head Loss Coefficient
Q	Discharge in m ³ /sec
v	Velocity in m/sec
SWD or d	Side Water Depth in m
b	Width in m
d	Diameter in m
L	Length in m

Formulae Used for Calculating Head Losses:

I. Frictional Losses in Open Channels:

Using Manning's Formula Hydraulic Gradient (S) = $\left[\frac{Velocity \times n}{R^{2/3}} \right]^{1/(1/2)}$

n = Manning's Coefficient

Hydraulic Radius (R) = $\frac{\text{Cross Sectional Area}}{\text{Wetted Perimeter}}$

$$= \frac{b \times d}{b + 2d}$$

Frictional Loss = Hydraulic Gradient (S) \times Length

II. Frictional Losses in Pipes:

a. Frictional Losses by Hazen William Equation:

✓ Assuming value of $C = 100$

$$h_{fr} = \left[\frac{\text{Velocity}}{0.85 \times C \times R^{0.63}} \right]^{1/0.54} \times \text{Length of Pipe}$$

Where, C = Hazen William Coefficient (Refer Table No.)

R = Hydraulic Radius

$$= \frac{\text{Diameter}}{4}$$

b. Frictional Losses by Darcy Weisbach Equation:

$$h_f = \left[\frac{f \times L \times Q^2}{12.1 \times d^5} \right]$$

Where, f = Darcy Weisbach Coefficient (Refer Table No.)

L = Length of Pipe in m

Q = Discharge in m³/sec

d = Diameter of Pipe in m

III. Minor Head Losses in Pipes:

a. Loss at Entry:

$$h_{en} = \frac{K_{en} \times V^2}{2 \times g}$$

b. Loss at Exit:

$$h_{ex} = \frac{K_{ex} \times V^2}{2 \times g}$$

c. Loss due to Bend:

$$h_b = \frac{K_b \times V^2}{2 \times g}$$

d. Loss due to Sudden Enlargement:

$$h_{se} = \frac{K_{se} \times V_1^2}{2 \times g}$$

e. Loss due to Sudden Contraction:

$$h_{sc} = \frac{K_{sc} \times V_2^2}{2 \times g}$$

Where K_{en} , K_{ex} , K_b , K_{se} , K_{sc} are Head Loss Coefficients

For Coefficient Details refer Table No.

v = velocity in m/sec

g = Gravitational Acceleration

Formulae Used for Calculating Water and Reduced Levels:

$$\text{TWL at Start of an Element} = \textit{Preceeding TWL}_{Element} - \textit{Assumed Drop}_{Element}$$

$$\text{TWL at End of an Element} = \textit{TWL}_{Element} \textit{ at start} - \textit{Total Head Loss}_{Element}$$

$$\text{RL at Start of an Element} = \textit{TWL}_{Element} \textit{ at start} - \textit{SWD}_{Element}$$

$$\text{RL at End of an Element} = \textit{TWL}_{Element} \textit{ at End} - \textit{SWD}_{Element}$$

HEAD LOSSES

- REDUCED LEVELS

**HEAD LOSSES AND REDUCED LEVELS
(CASCADE AERATOR)**

1. STEPS AND PLANNER

- ✓ No. of Steps = 5 Nos.
- ✓ Rise of Steps = 0.3 m
- ✓ Diameter of Aerator = 7.3 m

2. COLLECTION LAUNDER

- ✓ Velocity in Launder = 0.65 m/sec
- ✓ Width of Launder = 0.6 m
- ✓ SWD = 0.742
- ✓ Free Board = 0.3 m

HEAD LOSS CALCULATIONS AND LEVELS:

- R.L at Lip of Aeration Fountain = 150 m
- Free Fall from last step to collection launder = 0.01 m

$$\begin{aligned} \text{Total Loss from lip of fountain} &= (\text{No of Steps} \times \text{Rise}_{\text{Step}}) + \text{Free Fall} \\ &= (5 \times 0.3) + 0.01 \end{aligned}$$

$$\text{Total Loss from Lip of Fountain} = 1.510 \text{ m}$$

- Assumed Total Loss from Lip of Fountain = 1.510 m

$$\begin{aligned} \text{TWL of Collection Launder at start} &= \text{RL of Lip} - (\text{Total Loss} + \text{Additional Losses}) \\ &= 150 - (1.510 + 0.01) \end{aligned}$$

$$\text{TWL of Collection Launder at start} = 148.480 \text{ m}$$

$$\begin{aligned} \text{R.L of Collection Launder Bottom at start} &= \text{TWL of Collection Launder at start} - \text{SWD of Launder} \\ &= 148.480 - 0.742 \end{aligned}$$

$$\text{R.L of Collection Launder Bottom at start} = 147.738 \text{ m}$$

$$\begin{aligned} \text{R.L of Collection Launder Top at start} &= \text{TWL of Collection Launder at start} + \text{Free Board} \\ &= 148.468 + 0.3 \end{aligned}$$

$$\text{R.L of Collection Launder Top at start} = 148.038 \text{ m}$$

$$\begin{aligned} \text{Length of Launder} &= \frac{\pi}{2} \times (\text{Diameter}_{\text{Aerator}} + \text{Width}_{\text{Launder}}) \\ &= \frac{3.14}{2} \times (7.3 + 0.6) \end{aligned}$$

$$\text{Length of Launder} = 12.40 \text{ m}$$

- Frictional Loss in Launder, Using Manning's Formula and taking Manning's Coefficient for R.C.C as $n = 0.13$

$$\text{Hydraulic Gradient (S)} = \left[\frac{\text{Velocity} \times n}{R^{(2/3)}} \right]^{1/(1/2)}$$

$$= \left[\frac{0.6 \times 0.013}{0.21363^{(2/3)}} \right]^{1/(1/2)}$$

$$\text{Hydraulic Gradient (S)} = 0.00056$$

$$\text{Frictional Loss in Launder} = \text{Hydraulic Gradient} \times \text{Length of Launder}$$

$$= 0.00056 \times 12.40$$

$$\text{Frictional Loss in Launder} = 0.007 \text{ m}$$

$$\text{TWL of Collection Launder at End} = \text{TWL of Launder at Start} - (\text{Frictional Loss} + \text{Additional Loss})$$

$$= 148.480 - (0.007 + 0.005)$$

$$\text{TWL of Collection Launder at End} = 148.468 \text{ m}$$

$$\text{R.L of Collection Launder Bottom at End} = \text{TWL of Collection Launder at End} - \text{SWD}_{\text{Launder}}$$

$$= 148.468 - 0.742$$

$$\text{R.L of Collection Launder Bottom at End} = 147.726 \text{ m}$$

SOME PAGES ARE KEPT BLANK INTENTIONALLY

**HEAD LOSSES AND REDUCED LEVELS
(PURE WATER CHANNEL)**

- ✓ Velocity of Flow in Channel = 0.6 m/sec
- ✓ Depth of Water (SWD) = 0.482 m
- ✓ Length of Channel = 3 m
- ✓ Width of Channel = 2 m

HEAD LOSS CALCULATIONS AND LEVELS:

- TWL of Rapid Sand Gravity Filter at end = 146.435 m
- Assumed Drop in Channel = 0 m

$$\begin{aligned} \text{TWL of Channel at start} &= \text{TWL of Launder at End} - \text{Drop} \\ &= 146.435 - 0 \end{aligned}$$

$$\text{TWL of Channel at start} = 146.435 \text{ m}$$

$$\begin{aligned} \text{RL of Channel at Start} &= \text{TWL of Channel at Start} - \text{SWD}_{\text{Channel}} \\ &= 146.435 - 0.482 \end{aligned}$$

$$\text{RL of Channel at Start} = 145.953 \text{ m}$$

- Frictional Loss in Channel, Using Manning's Formula and taking Manning's Coefficient for R.C.C as $n = 0.13$

$$\begin{aligned} \text{Hydraulic Gradient (S)} &= \left[\frac{\text{Velocity} \times n}{R^{(2/3)}} \right]^{1/(1/2)} \\ &= \left[\frac{0.6 \times 0.13}{0.32524^{2/3}} \right]^{1/(1/2)} \end{aligned}$$

$$\text{Hydraulic Gradient (S)} = 0.00027$$

$$\begin{aligned} \text{Frictional Loss in Channel} &= \text{Hydraulic Gradient} \times \text{Length of Channel} \\ &= 0.00027 \times 3.00 \end{aligned}$$

$$\text{Frictional Loss in Channel} = 0.00081 \text{ m}$$

- Assumed Frictional Loss in Channel = 0.00081 m
- Assumed Additional Head Losses Remark = 0 m

$$\begin{aligned} \text{TWL of Channel at End} &= \text{TWL of Channel at Start} - (\text{Frictional Loss} + \text{Additional Loss}) \\ &= 146.435 - (0.00081 + 0) \end{aligned}$$

$$\text{TWL of Channel at End} = 146.434 \text{ m}$$

$$\text{R.L of Channel Bottom at End} = \text{R. L of Channel Bottom at Start}$$

$$\text{R.L of Channel Bottom at End} = 145.953 \text{ m}$$

**HEAD LOSSES AND REDUCED LEVELS
(PIPE)**

- ✓ *Designed Flow = 0.579 m³/sec*
- ✓ *Velocity of water in Pipe = 0.6 m/sec*
- ✓ *Diameter of Pipe = 1.200 m*
- ✓ *Length of Pipe = 3 m*

HEAD LOSS CALCULATIONS AND LEVELS:

➤ *TWL of Channel at end = 146.434 m*

$$\begin{aligned} \text{Total Head Losses in Pipe} &= A_{HL} \\ &= 0 \end{aligned}$$

$$\text{Total Head Losses in Pipe} = 0.000 \text{ m}$$

$$\begin{aligned} \text{TWL at the start of Pure Water Sump} &= \text{TWL of Pure Water Channel at end} - \text{Total Head Losses in Pipe} \\ &= 146.434 - 0.000 \end{aligned}$$

$$\text{TWL at the start of Pure Water Sump} = 146.434 \text{ m}$$

**HEAD LOSSES AND REDUCED LEVELS
(PURE WATER SUMP)**

✓ *Water Depth (SWD) = 3 m*

HEAD LOSS CALCULATIONS AND LEVELS:

➤ *TWL of Pure Water Sump at the start = 146.434 m*

$$\begin{aligned} \text{FSL in Sump} &= \text{TWL at Start} - (\text{Drop} + \text{Free Fall}) \\ &= 146.434 - (0.050 \text{ m} + 0.300 \text{ m}) \end{aligned}$$

$$\text{FSL in Sump} = 146.084 \text{ m}$$


$$\begin{aligned} \text{RL of Sump Bottom} &= \text{FSL in Sump} - \text{SWD}_{\text{Sump}} \\ &= 146.084 - 3 \end{aligned}$$


$$\text{RL of Sump Bottom} = 143.084 \text{ m}$$


TOTAL WATER LEVEL AND REDUCED LEVELS

AVERAGE GL OR RL AT START = 150 m

SR NO.	ELEMENT	CUMULATIVE HEAD LOSS	TOTAL WATER LEVEL		REDUCED LEVEL	
			START	END	START	END
1	CASCADE AERATOR	1.532 m	150	148.468	150	147.726
2	PARSHALL FLUME	1.991 m	148.468	148.009	147.322	147.459
3	FLASH MIXER	1.996 m	148.009	148.004	138.004	138.004
4	PIPE	2.011 m	148.004	147.989		
5	PIPE	2.011 m	147.989	147.989		
6	CLARIFLOCCULATOR	2.056 m	147.989	147.944	147.023	146.979
7	CHANNEL	2.061 m	147.944	147.939	146.657	146.653
8	FILTER INLET CHANNEL	2.062 m	147.939	147.938	147.112	147.112
9	RAPID SAND GRAVITY FILTER	3.565 m	147.938	146.435		145.338
10	PURE WATER CHANNEL	3.566	146.435	146.434	145.953	145.953
11	PIPE	3.566 m	146.434	146.434		
12	PURE WATER SUMP	3.916 m		146.434		143.084







TWL	150	148.480	148.468	148.457	148.016	148.009	148.004	147.988	147.988	147.944	147.939	147.938	147.938	146.434	146.084
RL	147.738	147.738	147.726	147.316	147.466	147.459	138.004	143.488	147.023	146.979	146.653	147.112	145.338	145.953	143.084